



# DYAL SINGH EVENING COLLEGE

(University of Delhi)

Phone: 011-24367658 Fax 01124369983 www.dsce.du.ac.in,

A Full-fledged Day College

(as per Executive Council Resolution No.8-35 of the University of Delhi)




Ref. No. 20/P/EC

Dated: 05.04.2024

## Public Notice

S.No.	Items	Qty.
1	3.5X240 sq PVC insulated and PVC sheathed Al armoured XLPE aluminum conductor cable power of 1.1 kb	240 mtrs.
2	250 amp Capacity on Load type manual change over switch unit in seat steek in enclosure on existing brick machinery pedestal/ structure with making.	1 nos.
3	415 V MCCB distribution board of sheet steel dust protected duly powder painted inclusive of 400 A aluminum bus bar common neutral link bar earth bar , din bar for mounting MCCBs (but without mccb and incomer) face outlets are required size 600x400x250	1 nos.
4	415 V MCCB distribution board of sheet steel dust protected duly powder painted inclusive of 400 A aluminum bus bar common neutral link bar earth bar , for mounting MCCBs (but without mccb inductor face outlets are required size 1200x600x300	1 nos.
5	Recess mounting, vertical type, board of sheet steel, dust protection, duly power painted, inclusive of aluminum, common neutral link, earth bar din bar, 250 amp, Euro control euro ATS Automatic transfer switch dual source fast instant switching with control signal terminals for automatic changeover.	1 nos.
6	Labour charges for connection in electric panel and laying cable	240 mtrs.

The work shall be carried out as per CPWD specifications. You are required to send the sealed quotation of rate as per latest DSR (E&M) 2022 for the same during the office hours in favour of The Principal, Dyal Singh Evening College, University of Delhi, New Delhi-110003 on or before 12.04.2024 upto 05.00 P.M.

  
(Prof. Bhawna Pardey)  
Principal

CC: College website.